

CLIENT: **EV MATERIALS CORP**
13065 North Knoll
Anaheim, CA 92801

Test Report No: RJ6280P-1

Date: June 13, 2018

SAMPLE ID: The client submitted and identified the following test samples as:
4 each, plastic pedestals approximately 52" high by 6" in diameter.

SAMPLING DETAIL: Test samples were submitted to the laboratory directly by the client. No special sampling conditions or sample preparation were observed by QAI.

DATE OF RECEIPT: Samples were received at QAI Laboratories on May 31, 2018.

TESTING PERIOD: June 8, 2018.

AUTHORIZATION: QAI Test Proposal Number 18MB05161 signed by Francis Hamele of EV Materials on May 17, 2018.

TEST REQUESTED: Pedestal Axial Load Test per Section 5 of CISC Recommended Test Procedures for Access Floors.

TEST RESULTS: Detailed test results are presented in the subsequent pages of this report

Tested By



Delmy Elias
Test Technician

**Signed for and on behalf of
QAI Laboratories, Inc.**



Larry Burmer
Physical Laboratory Supervisor

PEDESTAL AXIAL LOAD TEST PER SECTION 5 OF CISCA

Test Procedure

The test specimens were individually placed on a steel platform centered on a United compression/tension machine. An axial load was applied to the top of the specimen at a rate not exceeding 10,000 pounds per minute (44.5 kN/min) up to a load of 3,500 pounds (15.6 kN). The load was held for a minimum of 1 minute, released, and the test specimen examined for damage. The load was then increased in 500 pound increments up to a maximum test load of 5,000 pounds. The load was held for a minimum of 1 minute at each increment. A photograph of the test set-up is provided on page 3 of this report.

Test Requirements

Adjusting devices, locking devices and threads shall be workable by hand.

Test Results

Specimen No.	Specimen Height	Applied Load (lbs)				Observations
		3,500	4,000	4,500	5,000	
1	52"	Pass	Pass	Pass	Pass	Adjusting devices, locking devices and threads remained workable by hand.
2	52"	Pass	Pass	Pass	Pass	Adjusting devices, locking devices and threads remained workable by hand.
3	52"	Pass	Pass	Pass	Pass	Adjusting devices, locking devices and threads remained workable by hand.

PHOTOGRAPHS



Photograph No.1
52" Pedestal Axial Load Test Set-up

*****<<<END OF REPORT>>>*****

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED.